

## TESTING FOR THE VERIFICATION OF COMPLIANCE OF ENERGY STORAGE SYSTEM WITH : VDE-AR-N 4105:2018-11+ CORRECTION 1: 2020-10: GENERATORS CONNECTED TO THE LOW-VOLTAGE DISTRIBUTION NETWORK – TECHNICAL REQUIREMENTS FOR THE CONNECTION TO AND PARALLEL OPERATION WITH LOW-VOLTAGE DISTRIBUTION NETWORKS

Test Report Number .....: **SUEE240400004251**  
Type .....: Energy Storage System  
Trademark .....: ANKER  
Tested Model .....: **A17C1**  
Variant Models .....: A17C3

### APPLICANT

Name .....: **Anker Innovations Limited**  
Address .....: Room 1318-19, Hollywood Plaza, 610 Nathan Road, Mongkok, Kowloon, HongKong

### TESTING LABORATORY

Name .....: **SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch**  
Address .....: 1/F., Building 12, Xinxing Industry Park, No.78, Xinglin Street, Suzhou Industrial Park, Suzhou, Jiangsu, China

Conducted (tested) by .....: Horace Hao  
(Project Engineer)



Reviewed & Approved by .....: Colin Chen  
(Technical Reviewer)



Date of issue .....: **2024/04/09**  
Number of pages .....: 93  
Supplementary Report and pages .....: **SUEE240400004251** Attachment Report including 9 pages  
Total Number of pages .....: 102

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Member of the SGS Group (SGS SA)

TRF No. EEC\_ VDE-AR-N 4105

**Important Note:**

- This document is issued by the Company under its General Conditions of service accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- This document cannot be reproduced except in full, without prior approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes. The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client.

**Data Provided By The Client:**

The following data has been provided by the applicant:

1. Any information regarding technical characteristics of the equipment (ratings, operation modes, software and hardware versions, dimensions and weight).
2. Equipment operation & construction information (manuals, electrical diagrams, information about components, operation procedures).
3. Documental information (brand and models names, address or other information about applicant, company or manufacturer).
4. Other information remarked within this report.

SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch declines any responsibility with respect to the information provided by the applicant and that may affect the validity of results. It is not covered by A2LA accreditation.

**Test Report Historical Revision:**

Test Report Version	Date	Resume
SUEE240400004251	2024/04/09	First issuance

**INDEX**

<b>1</b>	<b>SCOPE .....</b>	<b>4</b>
<b>2</b>	<b>GENERAL INFORMATION .....</b>	<b>5</b>
2.1	Testing Period and Climatic conditions .....	5
2.2	Equipment under Testing .....	5
2.2.1	Reference Values .....	9
2.3	Manufacturer and Factory Information .....	9
2.4	Test Equipment List .....	10
2.5	Measurement Uncertainty .....	11
2.6	Test set up of the different standard .....	12
2.7	Definitions .....	15
<b>3</b>	<b>RESUME OF TEST RESULTS .....</b>	<b>16</b>
<b>4</b>	<b>TEST RESULTS .....</b>	<b>18</b>
4.1	System perturbations .....	18
4.1.1	Rapid voltage changes .....	18
4.1.2	Flickers .....	19
4.1.3	Harmonics and interharmonics .....	22
4.1.3.1	Harmonics .....	22
4.1.3.2	Interharmonics .....	24
4.1.3.3	Higher Frequency .....	24
4.1.4	Commutation notches .....	25
4.1.5	DC current injection .....	27
4.2	Three-phase inverter systems .....	28
4.2.1	Calculation of asymmetry of three-phase converters .....	28
4.2.2	Symmetrical operation with a symmetry device .....	28
4.3	Normal frequency operating range .....	28
4.4	RoCoF .....	31
4.5	Reactive power supply .....	35
4.5.1	Reactive power supply at $\Sigma S_{E_{max}}$ .....	35
4.5.2	Reactive power supply smaller than $P_{E_{max}}$ .....	42
4.6	Reactive power control .....	49
4.6.1	Reactive power voltage characteristic $Q(U)$ .....	49
4.6.2	Displacement factor/active power characteristic curve $\cos\phi(P)$ .....	49
4.6.3	Fixed displacement factor $\cos\phi(P)$ .....	51
4.7	Dynamic network stability .....	51
4.8	Active power output .....	51
4.8.1	Active power gradient .....	51
4.8.2	Ceasing of active power by external signal on input port .....	53
4.8.3	Active power steps .....	54
4.8.4	Active power adjustment at a function of grid frequency .....	55
4.8.4.1	Over-frequency .....	56
4.8.4.2	Under-frequency .....	61
4.8.5	Voltage-dependent active power reduction .....	65
4.9	Short-circuit contribution .....	65
4.10	Protection setting .....	66
4.11	Islanding detection .....	76
4.12	Connection conditions and synchronization .....	80
<b>5</b>	<b>PICTURES .....</b>	<b>83</b>
<b>6</b>	<b>ELECTRICAL SCHEME .....</b>	<b>92</b>
<b>7</b>	<b>CE DECLARATION .....</b>	<b>93</b>

## 1 SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch has been contracted by Anker Innovations Limited, in order to perform the testing according to:

- VDE-AR-N 4105:2018-11: "Generators connected to the low-voltage distribution network - Technical requirements for the connection to and parallel operation with low-voltage distribution networks" and including "Correction 1:2020-10".

As Test procedure, the following Standard has been used for some of the applicable tests of the Standard above:

- VDE V 0124-100:2020-06: Grid integration of generator plants Low-voltage – Test requirements for generation units, intended for connection and parallel operation on the low-voltage grid.

## 2 GENERAL INFORMATION

### 2.1 Testing Period and Climatic conditions

The necessary testing has been performed between the 28<sup>th</sup> of February of 2024 and the 03<sup>rd</sup> of April of 2024.

All the tests and checks have been performed at climatic conditions:

Temperature	25 ± 5 °C
Relative Humidity	50 ± 10 %
Pressure	96 ± 10 kPa

### 2.2 Equipment under Testing

Apparatus type ..... : Energy Storage System  
Installation ..... : Fixed installation  
Manufacturer ..... : Anker Innovations Limited  
Trademark ..... : ANKER  
Model / Type reference ..... : A17C1  
Serial Number ..... : APCGQ80E13200076  
Software Version..... : v.3.1.0  
Rated Characteristics..... : PV input: 16-60 V, Max. 4× 16 A  
Battery rated voltage: 16V, Max.: 75A  
AC output: L/N/PE 230 V, 50 Hz, 3.5 A, 800 W  
Date of manufacturing: 2023  
Input ..... : Battery and PV  
Output ..... : AC, L/N/PE  
Class of protection against electric shock...: Class I  
Degree of protection against moisture.....: IP 65  
Type of connection to the main supply ..... : Single phase – Fixed installation  
Cooling group..... : Natural Cooling  
Modular ..... : No  
Internal Transformer ..... : Yes

**Copy of marking plate (representative):**

**Anker SOLIX Solarbank 2 E1600 Pro**

Anker SOLIX Balcony Energy Storage System

Model: A17C1

<b>PV terminal</b>	<b>On-grid terminal</b>
Max. PV input voltage: 60Vd.c.	AC output power: 800W
Max. PV input current: 16Ad.c.(per chanel)	AC rated output: 220/230/240Va.c., 50/60Hz
Max. Isc. PV: 20Ad.c.	Max. AC output current: 3.5Aa.c., 230Va.c.
Max MPPT input power: 2400W	Power factor: 1(-0.8~+0.8)
Operation voltage range: 16-60Vd.c.	

**General parameters**

Ingress Protection: Class I  
 Operation temperature range: -20°C~+55°C  
 Enclosure: IP 65  
 Isolated method(solar): Isolated Transformer  
 Isolated method(battery): HF

**Battery terminal**

Battery rated voltage: 16Vd.c.  
 Max. charge current: 75Ad.c.  
 Max. discharge current: 75Ad.c.  
 Rated power: 1000W

**Back-up terminal**

Max. AC output power: 1000W  
 Max. AC apparent power: 1000VA  
 AC output: 4.4Aa.c.(max), 230Va.c., 50/60Hz  
 Power Factor: 1 (-0.8 ~ +0.8)

Anker Innovations Limited  
 Room 1318-19, Hollywood Plaza, 610 Nathan Road, Mongkok, Kowloon, Hong Kong  
 Anker Innovations Deutschland GmbH Georg-Muche-Strasse 3, 80807 Munich, Germany  
 Made in China



<p><b>ALWAYS HERE TO HELP</b>  <a href="https://www.anker.com">https://www.anker.com</a>   support@anker.com</p>	<p>DE (Anker SOLIX): +49 (800) 000 2522                  Mon-Fri 9:00 Uhr bis 17:00 Uhr</p> <p>USA: +1 (800) 988-7973                  Mon-Fri 7:00 am to 5:00 pm (PT)</p>
--	--

**Note:**

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.
3. Labels of other models are as the same with A17C1's except for the parameters of rating.

**Equipment Under Testing:**

- A17C1

**Variant models:**

- A17C3

The variant models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology.
- Same control algorithm.
- Output power within  $1/\sqrt{10}$  and 2 times of the rated output power of the EUT or Modular inverters.
- Same Firmware Version.

The models A17C1 and A17C3 have the same topology schematic and control solution code, except for the Back-UP circuit. The A17C3 model does not have a backup circuit and reduces 2 MPPTs, everything else is exactly the same.

The results obtained apply only to the particular sample tested that is the subject of the present test report.

The most unfavorable result values of the verifications and tests performed are contained herein.

Throughout this report a point (~~comma~~) is used as the decimal separator.

Following table shows the full ratings of all the models referenced in this report, marked in **bold letters** is the one subjected to testing:

<b>Model</b>	<b>A17C1</b>	<b>A17C3</b>
<b>PV Input</b>		
Max. input voltage	60 Vdc	
MPPT operating voltage range	16-60 Vdc	
Max. input current	16 *4 A	16 *2 A
<b>Battery Input</b>		
Battery rated voltage	16 V dc	
Battery Max. charge & discharge current	75 A	
Battery rated power	1000W	
<b>AC Output</b>		
Nominal grid voltage	L/N/PE, 230 Vac	
Nominal grid frequency	50 Hz	
Rated AC power	800 W	
Max. AC apparent power	800 VA	
Max. AC current	3.5 A	
Output power factor	1 default (adjustable+/-0.8)	
<b>AC Output (Back-up)</b>		
Nominal grid voltage	L/N/PE, 230 Vac	/
Nominal grid frequency	50Hz	/
Rated AC power	1000W	/
Max. AC apparent power	1000VA	/
Max. AC current	4.4 A	/
Output power factor	1 default (adjustable+/-0.8)	/
<b>General Data</b>		
Operating temperature range	-20 °C ~ +55 °C	
Protection degree	IP65	
Protective class	Class I	
Cooling method	Natural Cooling	
Topology	Isolated	



### 2.3 Reference Values

The values presented in the following table have been used for calculation of referenced values (p.u.; %) through the report.

Reference Values	
Rated power, <b>P<sub>n</sub> (P<sub>rE</sub>)</b> in kW	0.8
Rated apparent power, <b>S<sub>n</sub> (S<sub>rE</sub>)</b> in kVA	0.8
Max. power, <b>P<sub>max</sub> (P<sub>Amax</sub>   P<sub>Emax</sub>)</b> in kW	0.8
Max. apparent power, <b>S<sub>max</sub> (S<sub>Amax</sub>   S<sub>Emax</sub>)</b> in kVA	0.8
Rated wind speed (only WT), <b>v<sub>n</sub></b> in m/s	Not applicable
Rated current (determined), <b>I<sub>n</sub></b> in A	3.5
Rated output voltage, (phase to neutral) <b>U<sub>n</sub></b> in Vac	230
Note: In this report p.u. values are calculated as follows: -For Active & Reactive Power p.u values are reference to <b>P<sub>n</sub></b> -For Currents p.u values, the reference is always <b>I<sub>n</sub></b> -For Voltages p.u values, the reference is always <b>U<sub>n</sub>=230V<sub>L-N</sub></b>	

Note: Rated current is calculated as,  $I_n=800/230=3.5$  A

### 2.4 Manufacturer and Factory Information

**Manufacturer Name:**

Name ..... : Anker Innovations Limited  
 Address ..... : Room 1318-19, Hollywood Plaza, 610 Nathan Road, Mongkok, Kowloon, HongKong

**Factory Name:**

Name..... : Huizhou Blueway Electronics Co.Ltd.  
 Address ..... : No. 101, West Hechang 5th Road, Zhongkai High-Tech Development Zone, Huizhou, Guangdong, P.R.China

**2.5 Test Equipment List**

From	No.	Equipment Name	Trademark / Model No.	Equipment No.	Calibration Period
SGS	1	Power analyzer	ZLG/PA6004H-P0004-2159	SUZE600303	2023/11/05 to 2024/11/04
	2	Digital Oscilloscope	Tektronix / MSO46 4-BW-500	ATC550903	2023/07/13 to 2024/07/12
	3	Oscilloscope probe	Tektronix/C188090	ATC550904	2023/08/08 to 2024/08/07
	4	Current probe	HIOKI/CT6873	SUZE600807	2023/09/08 to 2024/09/07
	5	Current probe	HIOKI/CT6873	SUZE600808	2023/09/08 to 2024/09/07
	6	Voltage probe	CYBERTEK/CP1000A	SUZE600801	2023/09/08 to 2024/09/07
	7	Voltage probe	CYBERTEK/CP1000A	SUZE600802	2023/09/08 to 2024/09/07
	8	Temperature & Humidity meter	Testo/175-H1	SUZE601701	2023/05/09 to 2024/05/08
	9	Power analyzer	DEWTRON/TRIONet	SUZE600302	2023/08/10 to 2024/08/09

Note: All measurement equipment was used inside their corresponding calibration period. Copy of all calibration certificates are available at the laboratory for reference.


## 2.6 Measurement Uncertainty

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.

Magnitude	Uncertainty
Voltage measurement	±1.5 %
Current measurement	±2.0 %
Frequency measurement	±0.2 %
Time measurement	±0.2 %
Power measurement	±2.5 %
Phase Angle	±1°
Cosφ	±0.01
<p>Note1: Measurement uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.</p> <p>Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.</p>	

**2.7 Test set up of the different standard**

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.5. Current and voltage clamps have been connected to the inverter input / output for all the tests.

All the tests described in the following pages have used this specified test setup.

**The test bench used includes:**

EQUIPMENT	TRADEMARK / MODEL	RATED CHARACTERISTICS	OWNER / SN.
AC source	WAGO / WLPA-330150kVA-D-W	150 kVA max. 45-65 Hz	SUZE600101
DC source	EA/PSI 11500-60	1500 V, 60 A max.	SUZE600201
RLC load	KAIXIANG / AC400V-450.99kVA-RLC	450 kW, 450 kVAR	SUZE660101

Test Conditions		
Condition	Value	Comments
Point of measurement	EUT Output (Low Voltage)	Equipment enounced in section 2.5 of this report has been used in the point of measurement
Short circuit ratio at the measurement point ( $S_k / S_n$ )	$S_k / S_n = 150\text{kVA} / 0.8\text{kVA} = 187.5$	
If the PGU is connected directly to the medium-voltage grid and a step-up transformer is installed between the PGU and the grid (which is not part of the PGU), a standard transformer must be used, the rated apparent power of which corresponds at least to the rated apparent power of the PGU being evaluated.	Connect to LV grid only	
MV Tansformer: Short circuit Power	--	Not applicable measured in Low voltage side
MV Transformer: Network impedance Phase Angle	--	Not applicable measured in Low voltage side
MV Transformer : Service voltage $U_c$	--	Not applicable measured in Low voltage side
LV Isolation transformer : Nominal Power (kVA)	--	Transformer
LV Isolation transformer : Short circuit voltage $U_k$ (%)	--	Transformer
LV Isolation transformer : Tap position	--	Transformer
MV Side: Additional impedance	--	Not applicable measured in Low voltage side
LV Side: Additional impedance	Active $0.24 \Omega$ Reactive $0.16 \Omega$	
The THDSU of the voltage which includes all integer harmonics up to the 50th order must be smaller than 5%. It is measured as the 10-minute mean at the PGU terminals while the PGU is not generating any power.	See section 4.1.3.1 of this report	
The voltage, measured as a 10-minute mean at the PGU terminals, must lie within a range of $\pm 10\%$ of the rated voltage	0.20%	
The voltage unbalance, measured as a 10-minute mean at the PGU terminals, must be less than 2%.	--	Single-phase

Test Conditions		
Condition	Value	Comments
The grid frequency, measured as a 0.2 second mean, must lie within a range of $\pm 1\%$ of the rated frequency around the rated frequency. The rate of change of the grid frequency, measured as a 0.2 second mean, must be smaller than 0.2% of the rated frequency per 0.2 seconds.	Tested Max. Value 49.997Hz Tested Min. Value 49.990Hz Tested Avg. Value:49.994Hz	
Note 1: These test conditions have been used in all the test performed in Sections 4 of this report. Note 2: See also the test bench information table in this section		

## 2.8 Definitions

$I_n$	Nominal Current	$P$	Power
p.u	Per unit	$I$	Current
$P_n$	Nominal Power	$M$	Change for real power
$S_n$	Apparent Power	$N$	Change for reactive power
PGU	Power Generation Unit	$F$	Frequency
$P_{st}$	Short-term flicker strength	$Q_f$	Quality factor
$P_{lt}$	Long-term flicker strength	NS	Network and System
$C_{\psi_K}$	Flicker coefficient for continuous operation	Un	Nominal Voltage
$S_r$	Apparent Power Rated	PWHD	Partial weight harmonic distortion
$S_k$	Short-circuit Apparent Power	THD	Total harmonic distortion
$K_{imax}$	Maximum switching current factor	$Z_{test}$	Test circuit impedance at which the emission test
$Z_{ref}$	The reference impedance	EUT	Equipment under test
$P_{rE}$	rated active power	$S_{rE}$	rated apparent power
$S_{Amax}$	maximum apparent power of a power generation system	$S_{Emax}$	maximum apparent power of a power generation unit
$P_{Amax}$	maximum active power of the power generation system	$P_{Emax}$	maximum active power of the power generation unit
$P_{mom}$	instantaneous active power	$P_{AV, E}$	agreed active power of a connection for feed-in

### 3 RESUME OF TEST RESULTS

#### INTERPRETATION KEYS

- Test object does meet the requirement .....: **P** Pass
- Test object does not meet the requirement.....: **F** Fails
- Test case does not apply to the test object .....: **N/A** Not applicable
- To make a reference to a table or an annex. ....: See additional sheet
- To indicate that the test has not been performed .....: **N/P** Not performed

TEST REPORT SECTION	VDE V 0124-100:2020-06 CLAUSE	STANDARD REQUIREMENTS		RESULT
		VDE-AR-N 4105:2018-11		
		CLAUSE	TEST	
<b>4.1</b>	<b>5.2</b>	<b>5.4</b>	<b>Network connection</b>	<b>-</b>
4.1.1	5.2.2	--	Rapid Voltage Changes	P
4.1.2	5.2.3	--	Flickers	P
4.1.3	5.2.4	--	Harmonics and interharmonics	P
4.1.4	5.2.5	--	Commutation notches	P
4.1.5	5.2.6	--	Direct current feed	P
<b>4.2</b>	<b>5.3</b>	<b>5.6</b>	<b>Verification of the symmetry behaviour of converters</b>	<b>N/A</b>
4.2.1	5.3.2	--	Calculation of asymmetry of three-phase converters	N/A
4.2.2	5.3.3	--	Symmetrical operation with a symmetry device	N/A
<b>--</b>	<b>5.4</b>	<b>5.7</b>	<b>Behaviour of the power generation system at the network</b>	<b>N/A</b>
4.3	--	5.7.1	General ( <i>Normal frequency operating range</i> )	P
4.4	--	5.7.1	General ( <i>RoCoF</i> )	P
4.5.1	5.4.8.2	5.7.2.2	Reactive power supply at $\Sigma S_{E_{max}}$	P
4.5.2	--	5.7.2.3	Reactive power supply smaller than $P_{E_{max}}$	P
4.6.1	5.4.8.4	5.7.2.4 a) / 5.7.2.5	Reactive power voltage characteristic curve $Q(U)$ / Requirements for reactive power methods of type 2 systems (inverters only) and type 1 systems	N/A
4.6.2	5.4.8.3	5.7.2.4 b) / 5.7.2.5	Displacement factor/active power characteristic curve $\cos \phi$ (P) / Requirements for reactive power methods of type 2 systems (inverters only) and type 1 systems	P
4.6.3	--	5.7.2.4 c) / 5.7.2.5	Displacement factor $\cos \phi$ / Requirements for reactive power methods of type 2 systems (inverters only) and type 1 systems	P
4.7	5.8	5.7.3	Dynamic network stability	N/A
4.8.1	5.4.3.4	5.7.4.1	Active power output – General ( <i>P gradient</i> )	P
4.8.2	--	5.7.4.1	Active power output – General ( <i>Ceasing of P</i> )	P
4.8.3	5.4.3.3	5.7.4.2.2	Active power steps	P
4.8.4.1	5.4.5	5.7.4.2.3	Active power adjustment as a function of grid frequency ( <i>Overfrequency, storage</i> )	P
4.8.4.2	5.4.7	5.7.4.2.3	Active power adjustment as a function of grid frequency ( <i>Underfrequency, storage</i> )	P

Continue on the next page



4.8.5	--	5.7.4.4	Voltage-dependent active power reduction	N/A
4.9	--	5.7.5	Short circuit contribution	P
--	<b>5.5</b>	<b>6.5</b>	<b>Protection devices and protection settings</b>	<b>P</b>
4.10	5.5.7	6.5.2	Protective functions	P
4.11	5.5.10	6.5.3	Islanding detection	P
<b>4.12</b>	<b>5.6</b>	<b>8.3</b>	<b>Connection conditions and synchronisation</b>	<b>P</b>

Note:

**Decision Rule of Statements of conformity** evaluated according to Guidelines ILAC G8:09/2019 and IEC 115:2023 (4.3.3 / 4.4) & ISO/IEC Guide 98-4 (8.3.12).

**Decision Rules used: Binary Statement for Simple Acceptance** (Guard Band with respect to the limit  $w=0$ ).

**Specific Risk:** Probability of False Accept or Reject lower than 50 %, (PFA / PFR < 50 %)

Measurement uncertainty is not applied when statements of conformity is the simple acceptance.

**For more information see ILAC G8/09 & 115 Guidelines.**

## 4 TEST RESULTS

### 4.1 SYSTEM PERTURBATIONS

System perturbations have been measured with tests procedures from chapter 5.2 of the VDE V 0124-100:2020-06 standard to verify requirements specified in form E.5 of VDE AR-N 4105:2018-11.

#### 4.1.1 Rapid voltage changes

The point 5.2.2 of VDE V 0124-100:2020-06 refers to the standard DIN EN 61000-3-3 for the verification of the rapid voltage changes in equipment with a nominal current  $\leq 16$  A.

Test results offered have a reference grid impedance  $Z_{ref}$  of  $32^{\circ}$ .

		$d_c$ (%)	$d_{max}$ (%)	$T_{max}$ (ms)
Limits set under DIN EN 61000-3-11		3.3	4.0	500
100% Pn	Measured values at test impedance	0.000	0.000	0
66% Pn	Measured values at test impedance	0.000	0.000	0
33% Pn	Measured values at test impedance	0.000	0.000	0

Graphics of the results are same with the flickers, refer to the section paragraph 4.1.2 of this report.

#### 4.1.2 Flickers

The Flickers test has been performed according to the paragraph 5.4.3 of VDE-AR-N 4105:2018-11 and the paragraph 5.2.3 of VDE V 0124-100:2020-06. It has been taken the EN 61000-3-3 as reference standard due to the output current  $\leq 16$  A of the inverter. In addition of the requirements of this reference standard, VDE-AR-N 4105: 2011 requires a Plt value less or equal to 0.5.

In table below are offered the values measured:

	Limit	33% Pn	66% Pn	100% Pn
Pst	$\leq 1$	0.017	0.030	0.030
Plt	$\leq 0.5$	0.013	0.029	0.029
dc [%]	$\leq 3.30$	0.000	0.000	0.000
dmax [%]	4	0.000	0.000	0.000

As it can be seen in the next screenshots, this test has 12 steps and each step for 10min. The values took of Pst, Plt, dc and dmax are the most unfavorable of the 12 steps.

According to the standard, the flicker coefficient  $c_{\Psi k}$  must be determined for the impedance angle  $32^\circ$ .

The flicker coefficient is determined on the basis of the previously measured  $P_{st}$  values in accordance with the following formula:

$$c_{\Psi k} = P_{st} \times (S_k / S_n).$$

Whereby the following applies:

$P_{st}$  Short-term flicker value measured on the network substitute element;

$S_k$  Short circuit power of the network substitute element (during determination of the corresponding  $P_{st}$  values).

Checking the datasheet of the AC source (KEWELL / KACM-75-33):

$S_{k, fic} = 150$  kVA, and  $P_n = 0.8$  kW

Which leads us to the following relation:

$$S_k / S_n = 187.5$$

These tests are only based on a  $32^\circ$  network impedance angle.

$Z_{test}$  impedance test (Test method refer to IEC 61000-3-11):

$R_A = 0.24$  W;  $X_A = j 0.15$  W at 50 Hz;

$R_N = 0.16$  W;  $X_N = j 0.10$  W at 50 Hz.

The impedance test  $Z_{test}$  is the same that the reference impedance  $Z_{ref}$ .

It has also been calculated the flicker coefficient in function of different network impedance phase angles. These calculations are offered in the table below.

Network impedance phase angle, $\Psi_k$	$32^\circ$
Average active power	Flicker coefficient, C ( $\Psi_k$ , P)
P = 33%Pn	3.19
P = 66% Pn	5.63
P = 100% Pn	5.63

**Power=33% Pn**

Time (-)	1/Pst_L1 ()	1/Plt_L1 ()	Du_max_L1 (%)	Du_dc_L1 (%)	1/Du_duration_L1 (s)
2024/2/28 19:03	0.017		0	0	0
2024/2/28 19:13	0.013		0	0	0
2024/2/28 19:23	0.013		0	0	0
2024/2/28 19:33	0.013		0	0	0
2024/2/28 19:43	0.013		0	0	0
2024/2/28 19:53	0.013		0	0	0
2024/2/28 20:03	0.013		0	0	0
2024/2/28 20:13	0.013		0	0	0
2024/2/28 20:23	0.013		0	0	0
2024/2/28 20:33	0.013		0	0	0
2024/2/28 20:43	0.013		0	0	0
2024/2/28 20:53		0.013	0	0	0
2024/2/28 20:53	0.013		0	0	0

**Power=66% Pn**

Time (-)	1/Pst_L1 ()	1/Plt_L1 ()	Du_max_L1 (%)	Du_dc_L1 (%)	1/Du_duration_L1 (s)
2024/2/28 10:58	0.029		0	0	0
2024/2/28 11:08	0.029		0	0	0
2024/2/28 11:18	0.029		0	0	0
2024/2/28 11:28	0.029		0	0	0
2024/2/28 11:38	0.029		0	0	0
2024/2/28 11:48	0.029		0	0	0
2024/2/28 11:58	0.029		0	0	0
2024/2/28 12:08	0.030		0	0	0
2024/2/28 12:18	0.030		0	0	0
2024/2/28 12:28	0.030		0	0	0
2024/2/28 12:38	0.030		0	0	0
2024/2/28 12:48		0.029	0	0	0
2024/2/28 12:48	0.029		0	0	0

**Power=100% Pn**

Time (-)	1/Pst_L1 ()	1/Plt_L1 ()	Du_max_L1 (%)	Du_dc_L1 (%)	1/Du_duration_L1 (s)
2024/2/27 18:26	0.029		0	0	0
2024/2/27 18:36	0.030		0	0	0
2024/2/27 18:46	0.029		0	0	0
2024/2/27 18:56	0.029		0	0	0
2024/2/27 19:06	0.029		0	0	0
2024/2/27 19:16	0.029		0	0	0
2024/2/27 19:26	0.030		0	0	0
2024/2/27 19:36	0.030		0	0	0
2024/2/27 19:46	0.030		0	0	0
2024/2/27 19:56	0.029		0	0	0
2024/2/27 20:06	0.030		0	0	0
2024/2/27 20:16		0.029	0	0	0
2024/2/27 20:16	0.030		0	0	0

### 4.1.3 Harmonics and interharmonics

The current harmonics, interharmonics and supharmonics have been measured according to chapter 5.2.4 of VDE V 0124-100:2020-06, at the required power values.

#### 4.1.3.1 Harmonics


Standard EN 61000-3-2 has been taken as reference for harmonic limits.

Values measured for current harmonics, total harmonic distortion (THD) up to the 40<sup>th</sup> harmonic and Partial Weighted Harmonic Distortion (PWHC) from the 12<sup>th</sup> to the 40<sup>th</sup> harmonic is offered in the following table and graphs:


P (%P <sub>n</sub> )	0	10	20	30	40	50	60	70	80	90	100	Limit
Nr. / Order	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)	I(A)
2	0.013	0.013	0.014	0.013	0.013	0.013	0.013	0.012	0.011	0.010	0.008	1.080
3	0.059	0.059	0.059	0.066	0.072	0.081	0.090	0.099	0.107	0.116	0.124	2.300
4	0.009	0.011	0.009	0.009	0.009	0.008	0.007	0.008	0.008	0.007	0.006	0.430
5	0.034	0.036	0.036	0.035	0.036	0.035	0.033	0.031	0.030	0.029	0.028	1.140
6	0.004	0.003	0.004	0.004	0.004	0.003	0.003	0.003	0.003	0.003	0.003	0.300
7	0.021	0.021	0.022	0.020	0.021	0.021	0.019	0.019	0.019	0.018	0.018	0.770
8	0.005	0.005	0.004	0.004	0.004	0.004	0.005	0.004	0.004	0.004	0.004	0.230
9	0.015	0.015	0.012	0.013	0.012	0.014	0.014	0.014	0.014	0.015	0.015	0.400
10	0.005	0.004	0.004	0.005	0.004	0.005	0.005	0.005	0.005	0.004	0.004	0.184
11	0.010	0.011	0.011	0.011	0.010	0.009	0.010	0.010	0.010	0.010	0.010	0.330
12	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.004	0.003	0.003	0.153
13	0.009	0.009	0.010	0.010	0.010	0.010	0.009	0.009	0.009	0.009	0.009	0.210
14	0.003	0.002	0.003	0.002	0.003	0.002	0.003	0.003	0.003	0.003	0.003	0.131
15	0.005	0.005	0.004	0.004	0.004	0.005	0.005	0.005	0.005	0.005	0.005	0.150
16	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.115
17	0.004	0.004	0.004	0.004	0.003	0.003	0.003	0.004	0.003	0.004	0.004	0.132
18	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.102
19	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.118
20	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.092
21	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.107
22	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.084
23	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.098
24	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.077
25	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.004	0.004	0.090
26	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.071
27	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.004	0.083
28	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.066
29	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.005	0.078
30	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.003	0.003	0.003	0.003	0.061
31	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.073
32	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.004	0.003	0.058
33	0.006	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.006	0.068
34	0.003	0.003	0.004	0.004	0.004	0.003	0.003	0.004	0.003	0.004	0.004	0.054
35	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.064
36	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.051
37	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.005	0.005	0.005	0.061
38	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.048
39	0.006	0.006	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.058
40	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.004	0.046
THC (%)	0.079	0.080	0.080	0.084	0.089	0.096	0.103	0.110	0.117	0.125	0.132	23.000
PWHC(%)	0.111	0.109	0.108	0.107	0.107	0.106	0.108	0.108	0.106	0.109	0.111	23.000

Note: Harmonic orders 41 to 50 are not required by EN 61000-3-2, and only orders 2 to 40 were involved in calculating THC and PWHC

### Current Harmonics



### THC and PWHC



#### 4.1.3.2 Interharmonics

This test is not applicable according to paragraph 5.2.4 of standard VDE V 0124-100:2020-06, which states that inverters >75 A will have to perform current interharmonics test.

#### 4.1.3.3 Higher Frequency

This test is not applicable according to paragraph 5.2.4 of standard VDE V 0124-100:2020-06, which states that inverters >75 A will have to perform current higher frequencies (between 2 kHz and 9 kHz) test.



#### 4.1.4 Commutation notches


The point 5.2.5 of VDE V 0124-100:2020-06 requires verification of the commutation voltage dips in line-commutated inverters.

The equipment shall be operated in three operation points, and three 100ms oscillograms from each operation point shall be measured to check the commutation dips.


Limits and success criteria are specified in VDE-AR-N 4100:2019-04, section 5.4.

Most unfavorable test results for each operation point are presented in the following table:

Operating point	P measured (p.u)	$\hat{U}_n$ (V)	$\Delta U_{com}$ (V)	$d_{com}$ limit (%)	$d_{com}$ measured (%)
$25\%P_{E_{max}} < P < 35\%P_{E_{max}}$	0.300	236.2	+6.2	5.0	+2.7
$65\%P_{E_{max}} < P < 75\%P_{E_{max}}$	0.704	236.2	+6.2		+2.7
$90\%P_{E_{max}} < P$	0.997	236.2	+6.2		+2.7




Commutation notches test ( $65\%P_{Emax} < P < 75\%P_{Emax}$ )



$$d_{com} = (((|334|/1.414) - 230) / 230) * 100\% = +2.7\%$$

Commutation notches test ( $90\%P_{Emax} < P$ )



$$d_{com} = (((|-334|/1.414) - 230) / 230) * 100\% = +2.7\%$$

### 4.1.5 DC current injection

The point 5.2.6 of VDE V 0124-100:2020-06 refers to the standard DIN EN 61000-4-7 for the verification of the DC current feed into the low-voltage grid.

This test is only required for inverters without internal transformer.

The equipment shall be operated in the following points at the following active power levels:


- 30.0%  $P_{E_{max}} < P < 40.0\% P_{E_{max}}$
- 60.0%  $P_{E_{max}} < P < 70.0\% P_{E_{max}}$
- $P > 95.0\% P_{E_{max}}$

The network or network simulator used for the tests shall meet the following conditions:

- $U = U_n \pm 5.0\%$
- $f = 50.00 \pm 0.20$  Hz
- Voltage THD  $< 2.5\%$
- DC component of the voltage  $< 0.1\%$

Limits given in VDE-AR-N 4100:2019-04 for direct current feed in are 0.5% of the rated current, or 20 mA, whichever is higher.

Operating point	P measured (p.u)	U measured (p.u.)	f measured (Hz)	Iac measured (p.u)	Idc limit (mA)	Idc measured (mA)
30% $P_{E_{max}} < P < 40\%P_{E_{max}}$	0.339	1.000	50.000	0.353	20	3.68
60% $P_{E_{max}} < P < 70\%P_{E_{max}}$	0.660	1.001	50.000	0.670		3.73
$P > 95\%P_{E_{max}}$	0.985	1.002	50.000	0.995		3.48



## 4.2 THREE-PHASE INVERTER SYSTEMS

This chapter has been done taking into consideration requirements from chapter 5.6 and information of Annex A.4 of the VDE AR-N 4105:2018-11 standard. Chapter 5.3 of the VDE V 0124-100:2020-06 has been used as a testing procedure.

### 4.2.1 Calculation of asymmetry of three-phase converters

This test is not applicable according to the section 5.3.2 of the standard VDE V 0124-100:2020-06 due to this testing is only applied to three-phase converters.

### 4.2.2 Symmetrical operation with a symmetry device

This test is not applicable according to the section 5.3.3 of the standard VDE V 0124-100:2020-06 due to this testing is only applied to EZE and storage operating with a symmetry device.

## 4.3 NORMAL FREQUENCY OPERATING RANGE

According to the paragraph 5.7.1 of the VDE-AR-N 4105:2018-11, in the frequency range of 47.5 Hz to 51.5 Hz, power generation systems shall be capable of network parallel operation in compliance with the time-related minimum requirements given in Table 1.


**Table 1 – Frequency/time ranges for the proper operation of power generation systems**

Frequency range	Operating period
47,5 Hz to 49,0 Hz	≥ 30 min
49,0 Hz to 51,0 Hz	unlimited
51,0 Hz to 51,5 Hz	≥ 30 min


Test results are offered in the following tables and graphs:

Test no.	Voltage setpoint (%Un)	Voltage measured (%Un)	Frequency setpoint (Hz)	Frequency measured (Hz)	Min. time required (min)	Time measured (min)	Active power measured (%Pn)	Disconnection
1	100.0	100.2	47.5	47.50	≥30	30.5	99.4	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
2	100.0	100.1	51.5	50.00	Unlimited	5.0	99.5	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
3	100.0	100.1	51.5	51.50	≥30	30.5	99.7	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No


**Test 1 (V = 100%Un and F = 47.5 Hz)**



**Test 2 (V = 100%Un and F = 50.0 Hz)**



Test 3 (V = 100%Un and F = 51.5 Hz)



#### 4.4 RoCoF

This test has been done according to chapter 5.7.1 of the VDE AR-N 4105:2018-11 standard to verify that the EUT does not disconnect when submitted to frequency jumps.

For verification of this requirement, different tests have been done regarding different frequency jumps and different mobile time windows in the range 47.5 Hz – 51.5 Hz, at 100 %Pn:

- $\pm 2$  Hz/s for a mobile time window of 0.5 s
- $\pm 1.5$  Hz/s for a mobile time window of 1 s
- $\pm 1.25$  Hz/s for a mobile time window of 2 s


Test results are offered in the following tables and graphs:

Test 1: $\pm 2$ Hz/s					
	Start frequency (Hz)	Change desired (Hz/s)	Final Value (Hz)	Ramp (Hz/s)	Disconnection
Positive frequency drift	49.00	+2.00	51.00	+2.00	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES
Negative frequency drift	50.98	-2.00	49.00	-1.98	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES

Test 2: $\pm 1.5$ Hz/s					
	Start frequency (Hz)	Change desired (Hz/s)	Final Value (Hz)	Ramp (Hz/s)	Disconnection
Positive frequency drift	49.25	+1.50	50.75	+1.50	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES
Negative frequency drift	50.76	-1.50	49.25	-1.50	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES


Test 3: $\pm 1.25$ Hz/s					
	Start frequency (Hz)	Change desired (Hz/s)	Final Value (Hz)	Ramp (Hz/s)	Disconnection
Positive frequency drift	48.75	+1.25	51.24	+1.25	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES
Negative frequency drift	51.25	-1.25	48.75	-1.25	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES

**Test 1 (+2 Hz/s) - Positive frequency drift**



Time of change measured: 1000 ms


**Test 1 (-2 Hz/s) - Negative frequency drift**



Time of change measured: 1000 ms




**Test 2 (+1.5 Hz/s) - Positive frequency drift**




Time of change measured: 1000 ms

**Test 2 (-1.5 Hz/s) - Negative frequency drift**




Time of change measured: 1000 ms

**Test 3 (+1.25 Hz/s) - Positive frequency drift**



Time of change measured: 2000 ms

**Test 3 (-1.25 Hz/s) - Negative frequency drift**



Time of change measured: 2000 ms

## 4.5 REACTIVE POWER SUPPLY

### 4.5.1 Reactive power supply at $\Sigma S_{E_{max}}$

This test has been measured according to chapter 5.4.8.2 of VDE V 0124-100:2020-06 to verify requirements from chapter 5.7.2.2 of the VDE AR-N 4105:2018-11 standard. The aim of the test is to verify the following  $\cos\phi(U)$  characteristic and verify the maximum reactive power capacity of the EUT:




Figure 2 – Requirements for power generation units regarding the reactive power supply at the generator terminals  
( $\Sigma S_{E_{max}} \leq 4,6 \text{ kVA}$ )

For this test, 60s average measurements of the following operation points shall be taken at a voltage of 0.900 p.u., 1.000 p.u. and 1.100 p.u., with a 0.020 U p.u. accuracy:

#### FOR INVERTERS WITH $\Sigma S_{E_{max}} \leq 4.6 \text{ KVA}$

- $\cos \phi = 0.950$  (Underexcited and overexcited) and  $\cos \phi = 0.980$  (Underexcited and overexcited), at an active power value between 40%  $P_{E_{max}}$  and 60%  $P_{E_{max}}$  and at  $S_{E_{max}}$ .

$\cos \phi$  shall be configurable in steps of at least 0.01.

Measured average Q values tolerances are  $\pm 0.040$  of  $P_{E_{max}}$  of the Q setpoint for each  $\cos \phi$ .

Test results are offered in the following tables and graphs:

40%P <sub>E<sub>max</sub></sub> <P setpoint <60P <sub>E<sub>max</sub></sub>									
Test 1 (cos phi setpoint = 0.950 inductive)									
Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) (±0.040 of P <sub>E<sub>max</sub></sub> )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.513	+0.164	+0.168	+0.004	0.950	0.950	91.8
2	1.000	1.000	0.505	+0.164	+0.165	+0.001	0.950	0.950	94.0
3	1.100	1.100	0.498	+0.164	+0.166	+0.002	0.950	0.949	104.2
Test 2 (cos phi setpoint = 0.950 capacitive)									
Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) (±0.040 of P <sub>E<sub>max</sub></sub> )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.515	-0.164	-0.167	-0.003	0.950	0.951	78.8
2	1.000	1.000	0.506	-0.164	-0.167	-0.003	0.950	0.950	80.0
3	1.100	1.085	0.500	-0.164	-0.164	0.000	0.950	0.950	71.2
Test 3 (cos phi setpoint = 0.980 inductive)									
Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) (±0.040 of P <sub>E<sub>max</sub></sub> )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.514	0.102	0.104	+0.002	0.980	0.980	77.8
2	1.000	1.000	0.506	0.102	0.101	-0.001	0.980	0.980	80.0
3	1.100	1.100	0.499	0.102	0.102	0.000	0.980	0.980	82.2
Test 4 (cos phi setpoint = 0.980 capacitive)									
Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) (±0.040 of P <sub>E<sub>max</sub></sub> )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.514	-0.102	-0.126	-0.024	0.980	0.971	78.0
2	1.000	1.000	0.506	-0.102	-0.124	-0.022	0.980	0.971	80.0
3	1.100	1.100	0.499	-0.102	-0.120	-0.018	0.980	0.972	82.0

**S set point = SEmax**
**Test 1 (cos phi setpoint = 0.950 inductive)**

Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) ( $\pm 0.040$ of $P_{Emax}$ )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.951	+0.312	+0.326	+0.014	0.950	0.946	78.0
2	1.000	1.000	0.941	+0.312	+0.299	-0.013	0.950	0.953	80.0
3	1.100	1.100	0.933	+0.312	+0.275	-0.037	0.950	0.959	82.0

**Test 2 (cos phi setpoint = 0.950 capacitive)**

Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) ( $\pm 0.040$ of $P_{Emax}$ )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.952	-0.312	-0.286	+0.026	0.950	0.958	68.6
2	1.000	1.000	0.941	-0.312	-0.300	+0.012	0.950	0.953	75.2
3	1.100	1.100	0.933	-0.312	-0.314	-0.002	0.950	0.948	66.2


**Test 3 (cos phi setpoint = 0.980 inductive)**

Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) ( $\pm 0.040$ of $P_{Emax}$ )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.987	+0.199	+0.219	+0.019	0.980	0.976	77.0
2	1.000	1.000	0.977	+0.199	+0.192	-0.007	0.980	0.981	80.0
3	1.100	1.100	0.969	+0.199	+0.168	-0.031	0.980	0.985	83.0


**Test 4 (cos phi setpoint = 0.980 capacitive)**

Step	U setpoint (p.u.)	U measured (p.u.)	P Measured (p.u.)	Q Desired (p.u.)	Q Measured (p.u.)	Q Deviation (p.u.) ( $\pm 0.040$ of $P_{Emax}$ )	PF setpoint	PF measured	time measured (s)
1	0.900	0.900	0.979	-0.199	-0.181	+0.018	0.980	0.983	77.0
2	1.000	1.000	0.970	-0.199	-0.194	+0.005	0.980	0.981	80.0
3	1.100	1.100	0.962	-0.199	-0.204	-0.005	0.980	0.978	83.0


**40%P<sub>E<sub>max</sub></sub> < P setpoint < 60P<sub>E<sub>max</sub></sub>  
Test 1 (cos phi setpoint = 0.950 inductive) - Chart**




**40%P<sub>E<sub>max</sub></sub> < P setpoint < 60P<sub>E<sub>max</sub></sub>  
Test 2 (cos phi setpoint = 0.950 capacitive) - Chart**




**40%P<sub>E<sub>max</sub></sub> <P setpoint <60P<sub>E<sub>max</sub></sub>  
Test 3 (cos phi setpoint = 0.980 inductive) - Chart**




**40%P<sub>E<sub>max</sub></sub> <P setpoint <60P<sub>E<sub>max</sub></sub>  
Test 4 (cos phi setpoint = 0.980 capacitive) - Chart**



**S set point =  $S_{E_{max}}$   
Test 1 (cos phi setpoint = 0.950 inductive) - Chart**




**S set point =  $S_{E_{max}}$   
Test 2 (cos phi setpoint = 0.950 capacitive) - Chart**






**S set point =  $S_{E_{max}}$   
Test 3 (cos phi setpoint = 0.980 inductive) - Chart**




**S set point =  $S_{E_{max}}$   
Test 4 (cos phi setpoint = 0.980 capacitive) - Chart**



#### 4.5.2 Reactive power supply smaller than $P_{E_{max}}$

This test has been done to verify requirements from chapter 5.7.2.3 of the VDE AR-N 4105:2018-11 standard. The aim of the test is to verify the following P/Q characteristic:



Within the range of  $0 \leq P_{mom}/P_{E_{max}} < 0.100 / 0.200$  (or the agreed minimum technical power) the power generation unit shall not exceed the reactive power value at the generator terminals of 10 % of the active power value  $P_{E_{max}}$  (reactive power supply and consumption respectively).

Within the free working range, a reduction of the active power to the benefit of the reactive power is permitted.

The following tests have been done:

- Test 1: Power factor of 0.900 over-excited measuring steps of  $5\%P_n$
- Test 2: Power factor of 0.900 under-excited measuring steps of  $5\%P_n$
- Test 3: Power factor of 1.000 measuring steps of  $5\%P_n$
- Test 4: Power factor of 0.900 over-excited with  $20\%P_n$ ,  $50\%P_n$  and  $90\%P_n$  setpoints
- Test 5: Power factor of 0.900 under-excited with  $20\%P_n$ ,  $50\%P_n$  and  $90\%P_n$  setpoints

Tests 1, 2 and 3 have been performed to confirm that the equipment complies with the minimum capabilities. Tests 4 and 5 have been performed to check the dynamics of the reactive power provision.

- Only red triangle area is Required, with tolerance:  $\pm 4\%$  of  $P_{E_{max}}$
- When operated at  $< 20\% P_{E_{max}}$  (figure 5), or  $< 10\% P_{E_{max}}$  (figure 6), reactive power  $< 10\% P_{E_{max}}$

Note:


1. The unit can meet the requirements according to Figure 6, then the tests is completed with PF=0.9 instead of 0.95.
2. Tests 4 and 5 are not applicable according to the section 5.4.8.3 of the standard VDE V 0124-100:2020-06, due to for guided EZE dynamics: A test of the PT1 behavior of the transition dynamics specified in VDE-AR-N 4105: 2018-11 is not necessarily due to the required limitations of the active power gradient.

Test results are offered in the following tables and graphs:


Test 1 (cos phi setpoint = maximum inductive) (PF=0.9)							
P Setting (% P <sub>E<sub>max</sub></sub> )	U Measured (p.u.)	P Measured (p.u.)	Q Measured (p.u.)	S Measured (p.u.)	cos φ Measured	Q Desired (p.u.)	Δ Q (≤ ±0.04*P <sub>E<sub>max</sub></sub> )
0.0	1.000	0.012	0.086	0.131	0.135	--	--
5.0	1.000	0.064	0.027	0.121	0.921	--	--
10.0	1.000	0.114	0.050	0.160	0.915	0.048	+0.002
15.0	1.000	0.163	0.075	0.206	0.909	0.073	+0.002
20.0	1.000	0.213	0.100	0.257	0.904	0.097	+0.003
25.0	1.000	0.262	0.125	0.308	0.902	0.121	+0.004
30.0	1.000	0.311	0.147	0.360	0.904	0.145	+0.002
35.0	1.000	0.360	0.171	0.413	0.903	0.170	+0.001
40.0	1.000	0.409	0.198	0.467	0.900	0.194	+0.004
45.0	1.000	0.458	0.221	0.520	0.900	0.218	+0.003
50.0	1.000	0.507	0.243	0.573	0.902	0.242	+0.001
55.0	1.000	0.556	0.268	0.627	0.900	0.266	+0.002
60.0	1.000	0.604	0.294	0.681	0.899	0.291	+0.003
65.0	1.000	0.652	0.317	0.735	0.899	0.315	+0.002
70.0	1.000	0.701	0.338	0.787	0.900	0.339	-0.001
75.0	1.001	0.749	0.364	0.841	0.899	0.363	+0.001
80.0	1.001	0.797	0.388	0.894	0.899	0.387	+0.001
85.0	1.001	0.845	0.413	0.949	0.898	0.412	+0.001
90.0	1.001	0.892	0.431	0.999	0.900	0.436	-0.005
95.0	1.001	0.892	0.433	1.000	0.899	0.436 <sup>(1)</sup>	-0.003
100.0	1.001	0.892	0.432	0.999	0.900	0.436 <sup>(1)</sup>	-0.004

<sup>(1)</sup> Because of limited by apparent power, the active does not reach to 95%P<sub>E<sub>max</sub></sub> and 100%P<sub>E<sub>max</sub></sub>, when cos φ = 0.90, then the desired reactive power equals to 0.436 P<sub>E<sub>max</sub></sub>.

Setting  $\cos \varphi = 0.900$  (in steps of 5 %  $P_{Emax}$ )




Test 1 PQ Curve




Test 2 (cos phi setpoint = maximum capacitive) (PF=0.9)							
P Setting (% P <sub>Emax</sub> )	U Measured (p.u.)	P Measured (p.u.)	Q Measured (p.u.)	S Measured (p.u.)	cos φ Measured	Q Desired (p.u.)	Δ Q (≤ ±0.04*P <sub>Emax</sub> )
0.0	1.000	0.012	0.086	0.128	0.140	--	--
5.0	1.000	0.064	0.003	0.116	0.999	--	--
10.0	1.000	0.114	-0.046	0.157	0.926	-0.048	+0.002
15.0	1.000	0.163	-0.071	0.204	0.916	-0.073	+0.002
20.0	1.000	0.212	-0.096	0.254	0.911	-0.097	+0.001
25.0	1.000	0.262	-0.121	0.306	0.908	-0.121	0.000
30.0	1.000	0.311	-0.143	0.358	0.909	-0.145	+0.002
35.0	1.000	0.361	-0.168	0.411	0.907	-0.170	+0.002
40.0	1.000	0.410	-0.193	0.465	0.905	-0.194	+0.001
45.0	1.000	0.459	-0.217	0.519	0.904	-0.218	+0.001
50.0	1.000	0.508	-0.241	0.573	0.903	-0.242	+0.001
55.0	1.000	0.557	-0.264	0.626	0.904	-0.266	+0.002
60.0	1.000	0.605	-0.289	0.681	0.902	-0.291	+0.002
65.0	1.000	0.654	-0.313	0.735	0.902	-0.315	+0.002
70.0	1.000	0.702	-0.338	0.789	0.901	-0.339	+0.001
75.0	1.000	0.751	-0.358	0.841	0.903	-0.363	+0.005
80.0	1.001	0.799	-0.384	0.896	0.901	-0.387	+0.003
85.0	1.001	0.847	-0.408	0.950	0.901	-0.412	+0.004
90.0	1.001	0.891	-0.427	0.998	0.902	-0.436	+0.009
95.0	1.001	0.894	-0.426	1.000	0.903	-0.436 <sup>(1)</sup>	+0.010
100.0	1.001	0.894	-0.428	1.001	0.902	-0.436 <sup>(1)</sup>	+0.008

<sup>(1)</sup> Because of limited by apparent power, the active does not reach to 95%P<sub>Emax</sub> and 100%P<sub>Emax</sub>, when cos φ = 0.90, then the desired reactive power equals to 0.436 P<sub>Emax</sub>.

Setting  $\cos \varphi = 0.900$  (in steps of 5 %  $P_{Emax}$ )




Test 2 PQ Curve




Test 3 (cos phi setpoint = 1.000)							
P Setting (% P <sub>E<sub>max</sub></sub> )	U Measured (p.u.)	P Measured (p.u.)	Q Measured (p.u.)	S Measured (p.u.)	cos φ Measured	Q Desired (p.u.)	Δ Q (≤ ±0.04 * P <sub>E<sub>max</sub></sub> )
0.0	1.000	0.013	0.085	0.132	0.153	--	--
5.0	1.000	0.064	0.003	0.121	0.999	--	--
10.0	1.000	0.114	0.002	0.153	1.000	0.000	+0.002
15.0	1.000	0.164	-0.001	0.193	1.000	0.000	-0.001
20.0	1.000	0.213	0.000	0.237	1.000	0.000	0.000
25.0	1.000	0.263	0.003	0.282	1.000	0.000	+0.003
30.0	1.000	0.312	0.002	0.329	1.000	0.000	+0.002
35.0	1.000	0.361	0.001	0.376	1.000	0.000	+0.001
40.0	1.000	0.410	0.001	0.424	1.000	0.000	+0.001
45.0	1.000	0.459	0.002	0.472	1.000	0.000	+0.002
50.0	1.000	0.508	0.002	0.520	1.000	0.000	+0.002
55.0	1.000	0.557	0.001	0.568	1.000	0.000	+0.001
60.0	1.000	0.606	0.001	0.616	1.000	0.000	+0.001
65.0	1.000	0.654	0.001	0.664	1.000	0.000	+0.001
70.0	1.000	0.703	0.003	0.713	1.000	0.000	+0.003
75.0	1.000	0.751	0.002	0.761	1.000	0.000	+0.002
80.0	1.000	0.799	0.001	0.809	1.000	0.000	+0.001
85.0	1.001	0.847	0.001	0.856	1.000	0.000	+0.001
90.0	1.001	0.895	0.004	0.904	1.000	0.000	+0.004
95.0	1.001	0.943	0.003	0.952	1.000	0.000	+0.003
100.0	1.001	0.996	0.000	1.005	1.000	0.000	0.000

(1) Because of limited by apparent power, the active does not reach to 95%P<sub>E<sub>max</sub></sub> and 100%P<sub>E<sub>max</sub></sub>, when cos φ = 0.90, then the desired reactive power equals to 0.436 P<sub>E<sub>max</sub></sub>.

Setting  $\cos \varphi = 1.000$  (in steps of 5 %  $P_{Emax}$ )



Test 3 PQ Curve





## 4.6 REACTIVE POWER CONTROL


### 4.6.1 Reactive power voltage characteristic Q(U)

This test is not applicable according to the section 5.7.2.4 of the standard VDE AR-N 4105:2018-11, due to the Q(U) rule applies only to three-phase power generation units connected to the three-phase current system

### 4.6.2 Displacement factor/active power characteristic curve $\cos\phi(P)$

This test has been done to verify requirements presented in chapter 5.7.2.4 b) of the VDE AR-N 4105:2018-11. For this test, test procedure from chapter 5.4.8.3 of the VDE V 0124-100:2020-06 has been used.

The aim of the test is to verify the capacity of the EUT of controlling power factor using active power through the following characteristic:



**Figure 8 – Characteristic curve for type 2**  
 $\sum S_{E\max} \leq 4,6 \text{ kVA}$  and type 1, stirling  
 generator, fuel cell  $\sum S_{E\max} > 4,6 \text{ kVA}$

The test procedure for this characteristic and for guided EUT consists in performing two power steps, one from  $P \leq 20\% \text{ PrE}$  to  $P = 100\% \text{ PrE}$ , and then another one from  $P = 100\% \text{ PrE}$  to  $P \leq 20\% \text{ PrE}$ , waiting for the stationary values to settle for both steps.

The reactive power control for this characteristic curve method must be assessed with regard to stationary accuracy only. Maximum tolerance for Q is  $\pm 0.040 \text{ P p.u.}$

Dynamic accuracy for guided EUT is omitted due to the limitations of the prescribed active power gradients for active power setpoints changes (see section 4.8.1 of this Test Report). The active power gradient of the steps has to be measured and in compliance with the requirements of chapter 5.7.4.1 of the VDE AR-N 4105:2018-11 standard.

The power gradients shall occur when the P steps are commanded by a third party, such as the grid operator, and in cases of network security management.


In this case, the unit is Type 2 systems and meet the requirements according to Figure 8.

Test results are offered in the following tables and graphs:

Active Power Setting (% P <sub>E<sub>max</sub></sub> )	Active Power Measured (p.u.)	Reactive Power Measured (p.u.)	Reactive Power Desired (p.u.)	Reactive Power Deviation (p.u.) (<=±0.040 P p.u)	cos φ Measured	P gradient measured (%P <sub>A<sub>max</sub></sub> /s)
P ≤ 0.20	0.193	+0.003	0.000	+0.003	1.000	--
From 0.2 to 1.00	0.947 <sup>(1)</sup>	-0.299	-0.312 <sup>(2)</sup>	+0.013	0.954	+0.4%
From 1.00 to 0.20	0.193	+0.003	0.000	+0.003	1.000	-0.4%

<sup>(1)</sup> Because it is limited by apparent power, the active power does not reach to 100%P<sub>E<sub>max</sub></sub> when cos φ = 0.95.

<sup>(2)</sup> The desired reactive power is based on active power equalling to 95%P<sub>E<sub>max</sub></sub>.



### 4.6.3 Fixed displacement factor $\cos\phi(P)$

This test is used to verify requirements presented in chapter 5.7.2.4 c) of the VDE AR-N 4105:2018-11.

The results obtained for this test can be checked in sections 4.5.1 and 4.5.2 of this Test Report.

## 4.7 DYNAMIC NETWORK STABILITY

This test requirements are stated in chapter 5.7.3.3 of the VDE AR-N 4105:2018-11 standard, to verify the capacity of the EUT of riding through short-term voltage drops/rises without disconnection. Throughout the different clauses of the mentioned chapter, all the requirements for grid faults are presented. For this test, the procedure from chapter 5.8 of the VDE V 0124-100:2019-09 is used.

Section 5.8.1 of the test procedure specifies that the following generators are excluded from testing:

- Stirling generators and fuel cells, which in principle cannot provide dynamic grid support.
- Synchronous and non-synchronous generators, which are coupled directly or via a converter, with  $PrE \leq 50$  kW.

Since the EUT is a non-synchronous generator with  $PrE \leq 50$  kW, this test is considered not applicable.

## 4.8 ACTIVE POWER OUTPUT

### 4.8.1 Active power gradient

This test has been done in order to comply with requirements from chapter 5.7.4.1 of the VDE AR-N 4105:2018-11 standard testing procedure from chapter 5.4.3.4 of the VDE V 0124-100:2020-06 applying the correct limits has been used.


This chapter requires testing an active power step from 100%  $P_{Amax}$  to 5%  $P_{Amax}$  and another one from 5%  $P_{Amax}$  to 100%  $P_{Amax}$  for storage units with a power gradient between  $0.33\%P_{Amax}/s$  and  $0.66\%P_{Amax}/s$ .

Test results are presented in the table and graphs below:


Test at maximum power gradient		
Active Power step (Setpoint)	Gradient setting (% $P_{Amax}/s$ )	Active power gradient expected (% $P_{Amax}/s$ )
100.0% to 5.0% $P_{Amax}$	-0.65	$-0.66 < P \text{ grad} < -0.33$
5.0% to 100.0% $P_{Amax}$	+0.65	$0.33 < P \text{ grad} < 0.66$

Test at minimum power gradient		
Active Power step (Setpoint)	Gradient setting (% $P_{Amax}/s$ )	Active power gradient expected (% $P_{Amax}/s$ )
100.0% to 5.0% $P_{Amax}$	-0.35	$-0.66 < P \text{ grad} < -0.33$
5.0% to 100.0% $P_{Amax}$	+0.34	$0.33 < P \text{ grad} < 0.66$

**Output power change (100% to 5% to 100% of  $P_{Amax}$ ) –  $0.66\%P_{Amax}/s$**



**Output power change (100% to 5% to 100% of  $P_{Amax}$ ) –  $0.33\%P_{Amax}/s$**




**4.8.2 Ceasing of active power by external signal on input port**

This test has been done in order to comply with requirements from chapter 5.7.4.1 of the VDE AR-N 4105:2018-11 standard.

Generating units shall be equipped with a logic interface (“CAN (Controller Area Network)”) in order to cease active power output within 5 seconds following an instruction from the grid operator being received at the input port, irrespective of the power gradients from point 4.8.1 of this Test Report. Additionally, the interface may be used for network security management.

Test results are graphically shown as below.



### 4.8.3 Active power steps

This test has been done in order to comply with requirements from chapter 5.7.4.2.2 of the VDE AR-N 4105:2018-11 standard. In order to evaluate this requirement, testing procedure from chapter 5.4.3.3 of the VDE V 0124-100:2020-06 standard has been taken.


Active power will be reduced from 100%P<sub>Amax</sub> to the minimum active power possible in steps of 10% P<sub>Amax</sub> to check that the EUT does not disconnect during those steps.

For each step, wait 1 minute after the change of setpoint to allow the EUT to adjust to the new setpoint. After that, the active power shall be measured as a 1-minute average.

Test results are presented in the following table and graph:

Active Power step (%P <sub>rE</sub> )	Setpoint value		Actual value		Deviation (Limit ±5% P <sub>rE</sub> )	
	(kW)	(%P <sub>rE</sub> )	(kW)	(%P <sub>rE</sub> )	(kW)	(%P <sub>rE</sub> )
100.0	0.800	100.0	0.796	99.5	-0.004	-0.5
90.0	0.720	90.0	0.718	89.8	-0.002	-0.2
80.0	0.640	80.0	0.641	80.1	+0.001	+0.1
70.0	0.560	70.0	0.562	70.3	+0.002	+0.3
60.0	0.480	60.0	0.484	60.5	+0.004	+0.5
50.0	0.400	50.0	0.405	50.7	+0.005	+0.7
40.0	0.320	40.0	0.327	40.8	+0.007	+0.8
30.0	0.240	30.0	0.248	31.0	+0.008	+1.0
20.0	0.160	20.0	0.169	21.1	+0.009	+1.1
10.0	0.080	10.0	0.089	11.2	+0.009	+1.2
0.0	0.000	0.0	0.009	1.1	+0.009	+1.1


- Values above detailed are obtained as 1-minute mean after 1 minute since the setpoint was adjusted to the required active power step.
- Power change gradient set during testing: 0.50%P<sub>Amax</sub>/s



**4.8.4 Active power adjustment at a function of grid frequency**

The aim of the test is to demonstrate the response of the EUT due to a deviation in grid frequency from rated value in terms of speed (rise/settling time) and the active power gradient.


This test has been performed according to the point 5.7.4.2.3 of the VDE AR-N 4105:2018-11 standard, changing the parameters in the PGU control system.



Key

- $P_{E_{max}}$  highest active power of a power generation unit (10 min mean value)
- $P_{ref}$  equals  $P_{E_{max}}$  for type 1 power generation units or  $P_{nom}$  for type 2 power generation units at the moment when 50,2 Hz is exceeded.
- $\Delta P$  power change
- $f$  network frequency

**Figure 14 – Active power adjustment for type 1 and type 2 power generation units at over-frequency and under-frequency with a static value of 5 % and frequency limit values of 49,8 Hz and 50,2 Hz for starting the adjustment**



Key

- $P_{E_{max}}$  highest active power of a power generation unit (10 min mean value)
- $\Delta P$  power change
- $f$  network frequency

**Figure 15 – Active power adjustment for storage units at an over-frequency with a static value of 5 % and an under-frequency with a static value of 2 % and frequency limit values of 49,8 Hz and 50,2 Hz for starting the adjustment**

Frequency measurement accuracy for this test shall be  $\leq \pm 10\text{mHz}$

Tests for both over and underfrequency deviations have been done. For both tests, additional requirements shall be taken into consideration presented in the standard.

The initial delay ( $T_v$ ) of the steps shall be  $\leq 2\text{s}$ .

During a frequency step, certain conditions that shall be verified:

- After  $T_v + 0.1 \cdot (T_{\text{an}_{90\%}} - T_v)$ , a minimum of 9% of the required power gradient for that step has been reached.
- After  $T_{\text{an}_{90\%}}$ , a minimum of 90% of the required power gradient for that step has been reached.
- Settling time shall not exceed 20s with a tolerance band of 10% of the required setpoint.
- After the disconnection, when the frequency has returned to a value that allows a reconnection, a delay of at least 60s must elapse, and power shall be restored via a gradient  $\leq 10\% P_{\text{Emax}}/\text{min}$ .

(\*)  $T_{\text{an}_{90\%}}$  refers to rise time and  $T_v$  refers to initial delay.

Static accuracy for active power is  $\leq \pm 10\% P_{\text{Emax}}$ .

#### 4.8.4.1 Over-frequency

Test procedure from chapter 5.4.4 (for inverters) / 5.4.5 (for storage) of the VDE V 0124-100:2020-06 standard establishes two tests for certifying the power droop and the disconnection and reconnection conditions at different parameters:

- **For Inverters**

Regarding active power adjustment at over-frequency, the VDE AR-N 4105:2018-11 standard establishes that in the frequency range from 50.2/50.5 Hz to 51.5 Hz, active power shall be reduced with a power drop of 2-12%, and that the generation unit shall disconnect if 51.5 Hz is surpassed.

Default values for threshold frequency and droop are 50.2 Hz and 5%, respectively.

- Test 1:  $P = 100\% P_{\text{Emax}}$ , frequency threshold for power droop = 50.2 Hz, droop = 5%, test with disconnection and reconnection
- Test 2:  $P = 60\% P_{\text{Emax}}$ , threshold for power droop = 50.5 Hz, droop = 12%, test without disconnection

Note: The PV input port of inverter was supplied by a PV simulator source with I-V characteristic during the testing.

- **For storage unit**

Regarding active power adjustment at over-frequency, the VDE AR-N 4105:2018-11 standard establishes that in the frequency range from 50.2/50.5Hz to 51.5Hz, active power shall be reduced with a power drop of 5%, and that the storage unit shall disconnect if 51.5 Hz is surpassed.


- Test 3:  $P = 100\% P_{\text{Emax}}$ , frequency threshold for power droop = 50.2 Hz, droop = 5%, test with disconnection and reconnection
- Test 4:  $P = 60\% P_{\text{Emax}}$ , threshold for power droop = 50.5 Hz, droop = 5%, test without disconnection

Note: The battery input port of inverter was supplied by a simulator DC source with battery characteristic during the testing.




**Test-1: PV Unit characteristic – Start power ( $P_M$ ) = 100% $P_{E_{max}}$** 

Settings		$F_{start}$ (Hz)	50.2	$s = \frac{\Delta f}{f_n} / \frac{\Delta P}{P_{ref}}$		5%
		$F_{disconnect}$ (Hz)	51.5			
Steps				$P_M = 100\% P_{E_{max}}$		
Step	Frequency setting (Hz)	Active Power expected (% $P_{E_{max}}$ )	Frequency measured (Hz)	Active power measured (% $P_{E_{max}}$ )	Variation measured (% $P_{E_{max}}$ ) ( $\pm 10\% P_{E_{max}}$ )	
a)	50.00	100.0	50.00	99.8	-0.2	
b)	50.25	98.0	50.25	98.0	0.0	
c)	50.70	80.0	50.70	80.5	+0.5	
d)	51.40	52.0	51.40	53.1	+1.1	
e)	50.70	80.0	50.70	80.5	+0.5	
f)	50.25	98.0	50.25	98.0	0.0	
g)	50.00	100.0	50.00	99.6	-0.4	
h)	51.65	0.0	51.65	0.0	0.0	
--	Disconnection confirm (Yes or No)			Yes		
i)	50.15	0.0	50.15	0.0	0.0	
--	Reconnected confirm (Yes or No)			No		
j)	50.00	100.0	50.00	99.8	-0.2	
--	Reconnection Time (s)		64.7			
--	Power gradient limited during step j ( $\leq 10\% P_{E_{max}}/\text{min}$ )					
--	Power gradient measured (% $P_{E_{max}}/\text{min}$ )		9.0			

**Active power feed-in at overfrequency ( $P_M = 100\% P_{E_{max}}$ )**


- Test-2: PV Unit characteristic – Start power ( $P_M$ ) = 60% $P_{E_{max}}$ 


Settings		$F_{start}$ (Hz)	50.5	$s = \frac{\Delta f}{f_n} / \frac{\Delta P}{P_{ref}}$	12%
		$F_{disconnect}$ (Hz)	51.5		
Steps				$P_M = 60\% P_{E_{max}}$	
Step	Frequency setting (Hz)	Active Power expected (% $P_{E_{max}}$ )	Frequency measured (Hz)	Active power measured (% $P_{E_{max}}$ )	Variation measured (% $P_{E_{max}}$ ) ( $\pm 10\% P_{E_{max}}$ )
a)	50.00	60.0	50.00	60.1	+0.1
b)	50.40	60.0	50.40	60.1	+0.1
c)	50.70	58.0	50.70	58.6	+0.6
d)	51.40	51.0	51.40	51.7	+0.7
e)	50.70	58.0	50.70	58.5	+0.5
f)	50.40	60.0 to 100.0 stable at 100.0	50.40	99.4	-0.6
--	Power gradient limited during step f ( $\leq 10\% P_{E_{max}}/\text{min}$ )				
	Power gradient measured (% $P_{E_{max}}/\text{min}$ )			8.8	
g)	50.00	100.0	50.00	99.3	-0.7

 Active power feed-in at overfrequency ( $P_M = 60\% P_{E_{max}}$ )


- **Test-3: Storage Unit characteristic – Start power (P<sub>M</sub>) = 100%P<sub>E</sub>max**


Settings		F <sub>start</sub> (Hz)	50.2	$s = \frac{\Delta f}{f_n} / \frac{\Delta P}{P_{ref}}$	5%
		F <sub>disconnect</sub> (Hz)	51.5		
Steps			P <sub>M</sub> = 100% P <sub>E</sub> max		
Step	Frequency setting (Hz)	Active Power expected (%P <sub>E</sub> max)	Frequency measured (Hz)	Active power measured (%P <sub>E</sub> max)	Variation measured (%P <sub>E</sub> max)
a)	50.00	100.0	50.00	99.7	-0.3
b)	50.25	98.0	50.25	98.2	+0.2
c)	50.70	80.0	50.70	80.6	+0.6
d)	51.40	52.0	51.40	53.0	+1.0
e)	50.70	80.0	50.70	80.6	+0.6
f)	50.25	98.0	50.25	98.1	+0.1
g)	50.00	100.0	50.00	99.5	-0.5
h)	51.65	0.0	51.65	0.0	0.0
--	Disconnection confirm (Yes or No)			Yes	
i)	50.15	0.0	50.15	0.0	0.0
--	Reconnected confirm (Yes or No)			No	
j)	50.00	100.0	50.00	99.7	-0.3
--	Reconnection Time (s)			64.5	
--	Power gradient limited during step j (<= 10%P <sub>E</sub> max/min)				
--	Power gradient measured (%P <sub>E</sub> max /min)			9.0	

**Active power feed-in at overfrequency (P<sub>M</sub> = 100% P<sub>E</sub>max)**



- Test-4: Storage Unit characteristic – Start power ( $P_M$ ) = 60% $P_{E_{max}}$ 

Settings		$F_{start}$ (Hz)	50.5	$s = \frac{\Delta f}{f_n} / \frac{\Delta P}{P_{ref}}$	5%
		$F_{disconnect}$ (Hz)	51.5		
Steps			$P_M = 60\% P_{E_{max}}$		
Step	Frequency setting (Hz)	Active Power expected (% $P_{E_{max}}$ )	Frequency measured (Hz)	Active power measured (% $P_{E_{max}}$ )	Variation measured (% $P_{E_{max}}$ ) ( $\pm 10\% P_{E_{max}}$ )
a)	50.00	60.0	50.00	60.0	0.0
b)	50.40	60.0	50.40	60.0	0.0
c)	50.70	52.0	50.70	55.6	+3.6
d)	51.40	38.4	51.40	39.2	+0.8
e)	50.70	52.0	50.70	55.6	+3.6
f)	50.40	60.0 to 100.0 stable at 100.0	50.40	99.4	-0.6
Power gradient limited during step f ( $\leq 10\% P_{E_{max}}/\text{min}$ )					
--	Power gradient measured (% $P_{E_{max}}/\text{min}$ )		8.8		
g)	50.00	100.0	50.00	99.3	-0.7

**Active power feed-in at overfrequency ( $P_M = 60\% P_{E_{max}}$ )**


#### 4.8.4.2 Under-frequency

Test procedure from chapter 5.4.6 (for inverters) / 5.4.7 (for storage) of the VDE V 0124-100:2020-06 standard establishes two tests for verification the power droop and the disconnection and reconnection conditions at different parameters:

- **For Inverters**

Regarding active power adjustment at underfrequency, the VDE AR-N 4105:2018-11 standard states that under 49.8 Hz, active power shall be increased with a power gradient of  $40\%P_{\text{Pref}} / \text{Hz}$ . If frequency is reduced under 47.5 Hz, the generation unit shall disconnect.

- Test 1:  $P = 10\% P_{\text{Emax}}$ , test with disconnection and reconnection
- Test 2:  $P = 60\% P_{\text{Emax}}$ , test without disconnection

- **For storage unit**


Regarding active power adjustment at underfrequency, the VDE AR-N 4105:2018-11 standard states that under 49.8 Hz, active power shall be increased with a power gradient of  $100\%P_{\text{Pref}} / \text{Hz}$ . If frequency is reduced under 47.5 Hz, the storage unit shall disconnect.

- Test 3:  $P = -100\% P_{\text{Emax}}$ , test with disconnection and reconnection\*
- Test 4:  $P = 10\% P_{\text{Emax}}$ , test without disconnection

\*The product has no AC charging function.


**Test-1: PV Unit characteristic – Start power ( $P_M$ ) = 10% $P_{E_{max}}$** 

Settings		$F_{start}$ (Hz)	49.8	$s = \frac{\Delta f}{f_n} / \frac{\Delta P}{P_{ref}}$	5%
		$F_{disconnect}$ (Hz)	47.5		
Steps			$P_M = 10\% P_{E_{max}}$		
Step	Frequency setting (Hz)	Active Power expected (% $P_{E_{max}}$ )	Frequency measured (Hz)	Active power measured (% $P_{E_{max}}$ )	Variation measured (% $P_{E_{max}}$ ) ( $\pm 10\% P_{E_{max}}$ )
a)	50.00	10.0	50.00	10.1	+0.1
b)	49.75	12.0	49.75	12.4	+0.4
c)	48.80	50.0	48.80	49.9	-0.1
d)	47.60	98.0	47.60	96.5	-1.5
e)	48.80	50.0	48.80	49.8	-0.2
f)	49.75	12.0	49.75	12.4	+0.4
g)	50.00	10.0	50.00	10.1	+0.1
h)	47.35	0.0	47.35	0.0	0.0
--	Disconnection confirm (Yes or No)		Yes		
i)	47.45	0.0	47.45	0.0	0.0
--	Reconnected confirm (Yes or No)		No		
j)	50.00	10.0	50.00	10.1	+0.1
--	Reconnection Time (s)		64.8		
--	Power gradient limited during step j ( $\leq 10\% P_{E_{max}}/\text{min}$ )				
--	Power gradient measured (% $P_{E_{max}}/\text{min}$ )		9.2		

**Active power feed-in at underfrequency ( $P_M = 10\% P_{E_{max}}$ )**


- Test-2: PV Unit characteristic – Start power ( $P_M$ ) = 60% $P_{E_{max}}$ 


Settings		$F_{start}$ (Hz)	49.8	$s = \frac{\Delta f}{f_n} \bigg/ \frac{\Delta P}{P_{ref}}$	5%
		$F_{disconnect}$ (Hz)	47.5		
Steps				$P_M = 60\% P_{E_{max}}$	
Step	Frequency setting (Hz)	Active Power expected (% $P_{E_{max}}$ )	Frequency measured (Hz)	Active power measured (% $P_{E_{max}}$ )	Variation measured (% $P_{E_{max}}$ ) ( $\pm 10\% P_{E_{max}}$ )
a)	50.00	60.0	50.00	60.4	+0.4
b)	49.75	62.0	49.75	62.7	+0.7
c)	48.80	100.0	48.80	99.1	-0.9
d)	47.60	100.0	47.60	99.0	-1.0
e)	48.80	100.0	48.80	99.1	-0.9
f)	49.85	60.0	49.85	60.4	+0.4
g)	50.00	60.0	50.00	59.9	-0.1

 Active power feed-in at underfrequency ( $P_M = 60\% P_{E_{max}}$ )


- Test-4: Storage Unit characteristic – Start power ( $P_M$ ) = 10% $P_{E_{max}}$

Settings		$F_{start}$ (Hz)	49.8	$s = \frac{\Delta f}{f_n} \cdot \frac{\Delta P}{P_{ref}}$	2%
		$F_{disconnect}$ (Hz)	47.5		
Steps				$P_M = 10\% P_{E_{max}}$	
Step	Frequency setting (Hz)	Active Power expected (% $P_{E_{max}}$ )	Frequency measured (Hz)	Active power measured (% $P_{E_{max}}$ )	Variation measured (% $P_{E_{max}}$ ) ( $\pm 10\% P_{E_{max}}$ )
a)	50.00	10.0	50.00	10.1	+0.1
b)	49.75	15.0	49.75	15.1	+0.1
c)	48.80	100.0	48.80	99.2	-0.8
d)	47.60	100.0	47.60	99.1	-0.9
e)	48.80	100.0	48.80	99.1	-0.9
f)	49.85	10.0	49.85	10.1	+0.1
g)	50.00	10.0	50.00	10.1	+0.1

Active power feed-in at underfrequency ( $P_M = 10\% P_{E_{max}}$ )





**4.8.5 Voltage-dependent active power reduction**

This test is not required according to the section 5.7.4.4 of the standard VDE AR-N 4105:2018-11 due to reduce the active power feed-in as a function of the voltage of (a) power generation unit(s) is optional.


**4.9 SHORT-CIRCUIT CONTRIBUTION**

According to the paragraph 5.7.5 of the VDE-AR-N 4105:2018-11, due to the operation of a power generation system, the short-circuit current of the low-voltage network is increased by the short-circuit current of the power generation system. Therefore, the short-circuit current of the power generation system to be expected at the network connection point shall be indicated in accordance with 4.2. For the determination of the initial short-circuit AC current contribution I<sub>kA</sub> of a power generation system, the following roughly estimated values can be assumed:

- for synchronous generators: 8 times the rated current;
- for asynchronous generators: 6 times the rated current;
- for generators and storage units with inverters: the rated current.

If the power generation system causes a short-circuit current increase in the network operator's network in excess of the rated value, then connection owner and network operator shall agree upon appropriate measures limiting the short-circuit current from the power generation system accordingly.

Short circuit current	
Short Circuit Applied	Isc Max (A)
Phases (L to N)	9.05 A



#### 4.10 PROTECTION SETTING

As indicated in VDE-AR-N 4105:2018-11, section 6 (*Construction of the power generation system/network and system protection (NS protection)*), the requirements for the network and system protection differ depending on the maximum apparent power ( $S_{Amax} \sum S_{Amax}$ ) of the generating and storage units connected to the same network connection point.

- For installations with  $S_{Amax} \sum S_{Amax} \leq 30\text{kVA}$ , the NS protection can either be
  - a central NS protection at the central meter panel or decentralized in a sub-distribution;
  - or
  - integrated NS protection

The equipment covered by this Test Report are all below this limit and both of these options can be chosen.

- For installations with  $S_{Amax} \sum S_{Amax} > 30\text{kVA}$ , the NS protection must be accomplished by a central NS protection device at the central meter panel.

In the case of the equipment covered by this Test Report, this will happen when several units are connected to the same network connection point.

In any case, the NS protection shall meet that a single fault shall not lead to a loss of the protective function (single fault tolerance).

All the tests in this section have been performed without an additional relay connected, to check the internal protection of the equipment.

This test has been done according to requirements presented in chapter 6.5 of the VDE AR-N 4105:2018-11 standard.

Testing procedure from chapter 5.5.7 of the VDE V 0124-100:2020-06 has been used for determining the trip value and the trip time as follows:

For  $U_{>>}$ ,  $U_{<}$  and  $U_{<<}$  tests:

- For testing the accuracy of threshold: Starting from a voltage level 2.0%  $U_n$  below or above the trip value of the protection function to be tested, the voltage is increased or decreased in steps of 0.5%  $U_n$  or less for at least the trip time stated in the protection function to be tested + 200ms (taking into account the maximum 100ms delay for the NS + interface switch), and the voltage at which the EUT trips is to be recorded
- For testing the accuracy of the trip time: Starting from a voltage value 2.0%  $U_n$  below or above the expected trip value, the voltage shall be increased in a single step to a value 2.0%  $U_n$  above or below that value. The time taken from the start of the step until the EUT trips is recorded as the trip time.

For the  $U_{>}$  tests (tests number 3.1, 3.2 and 3.3) the procedure is the following:

- For test 3.1: Starting from  $U_n$ , a single step to 112.0%  $U_n$  is performed. The expected behaviour is tripping of the EUT between 450.0s and 550.0s from the start of the step. Each step shall be maintained for at least 600.2s
- For test 3.2: Starting from 100.0%  $U_n$ , a single step to 108.0%  $U_n$  is performed. The expected behaviour of the EUT is no-tripping. Each step shall be maintained for at least 600.2s

- For test 3.3: Starting from 106.0%  $U_n$ , a single step to 114.0%  $U_n$  is performed. The expected behaviour is tripping of the EUT between 225.0s and 375.0s from the start of the step. Each step shall be maintained for at least 600.2s

For over/underfrequency tests:

- For testing the accuracy of threshold: Starting from a voltage level 0.10 Hz below or above the trip value of the protection function to be tested, the voltage is increased or decreased in steps of 0.05%  $f_n$  or less for at least the trip time stated in the protection function to be tested + 200ms (taking into account the maximum 100ms delay for the NS + interface switch), and the voltage at which the EUT trips is to be recorded
- For testing the accuracy of the trip time: Starting from a voltage value 0.10 Hz below or above the expected trip value, the voltage shall be increased in a single step to a value 0.10 Hz above or below that value. The time taken from the start of the step until the EUT trips is recorded as the trip time.

The permissible tolerance for the trip value tests is 1.0%  $U_n$  for voltage tests and 1.0%  $f_n$  for the frequency tests.

The trip time tests results shall be within the requirements of Table 2 from chapter 6.5.2 of VDE-AR-N 4105: 2018-11.

Protective function	Setting values for protection relays <sup>a</sup>					
	Stirling generators, fuel cells		Directly coupled synchronous and asynchronous generators with $P_n > 50$ kW		Inverter(s)	
	Synchronous and asynchronous generators with $P_n \leq 50$ kW coupled directly or via inverters					
Rise-in-voltage protection $U >>$	$1,15 U_n$	$\leq 100$ ms	$1,25 U_n$	$\leq 100$ ms	$1,25 U_n$	$\leq 100$ ms
Rise-in-voltage protection $U >$	$1,10 U_n^b$	$\leq 100$ ms	$1,10 U_n^b$	$\leq 100$ ms	$1,10 U_n^b$	$\leq 100$ ms
Voltage drop protection $U <$	$0,8 U_n^c$	$\leq 100$ ms	$0,8 U_n$	$1,0 s^d$	$0,8 U_n$	$3,0$ s
Voltage drop protection $U <$	Not applicable		$0,45 U_n$	$300$ ms <sup>d</sup>	$0,45 U_n$	$300$ ms
Frequency decrease protection $f <$	$47,5$ Hz	$\leq 100$ ms	$47,5$ Hz	$\leq 100$ ms	$47,5$ Hz	$\leq 100$ ms
Frequency increase protection $f >$	$51,5$ Hz	$\leq 100$ ms	$51,5$ Hz	$\leq 100$ ms	$51,5$ Hz	$\leq 100$ ms

<sup>a</sup> The duration set-point " $< 100$  ms" for the protection relay setting value is based on the assumption that the maximum response time for NS protection + interface switch is also 100 ms. This results in a maximum "total disconnection time" of 200 ms. If the response time of the components is  $< 100$  ms (e. g. 50 ms), then this allows for a longer period during which to perform the measurements and the evaluation of the protective function (e. g. up to 150 ms). This would then result in a protection relay setting value higher than " $< 100$  ms", i. e. " $< 150$  ms". However, in that case, only the 100 ms shall be visualised as the setting value at the NS protection. Nevertheless, the disconnection time of 200 ms shall in no case be exceeded.

<sup>b</sup> It shall be ensured, that the voltage  $1,10 U_n$  is not exceeded at the network connection point. If compliance with this requirement is ensured by a central NS protection, then it is permissible to set the rise-in-voltage protection at the decentralised power generation unit/system to a value of up to  $1,15 U_n$ . In that case, the system installer should consider any potential effects on the customer installation. Combination of central NS protection ( $U >: 1,1 U_n$ ) and integrated NS protection ( $U >: 1,1 U_n$  to  $1,15 U_n$ ) is recommended, if the voltage drop in the house installation cannot be neglected. This is typically the case with longer connection lines.

<sup>c</sup> For the protection of the power generation unit, disconnection may also be realised by means of an additional self-protection setting value (e. g.  $0,83 U_n$ ) before the setting value of  $0,8 U_n$  is reached.

<sup>d</sup> Where the medium-voltage network of the network operator upstream of the power generation system is operated with automatic reclosing (AWE, de: automatische Wiedereinschaltung), the following protective settings are recommended:  $U <<$ -Relay:  $0,45 U_{NS}$ , undelayed (i. e. shortest possible time delay) and  $U <$ -Relay:  $0,8 U_{NS}$ , 300 ms. The requirement is specified by the network operator.

Results are presented in the following tables:

Test No.	Protective function	Ramp or leap	Use on	Start value (p.u.)	End value (p.u.)	Step height $\Delta U$ (p.u.)	Step duration $n \Delta t$	Expected trip value (p.u.)	Measured trip value (p.u.)	Disconnection
1.2	U>>	Ramp	L to N	<1.230	>1.270	<0.005	>400 ms	1.250	1.248	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
4.2	U<	Ramp	L to N	>0.820	<0.780	<0.005	>3.2 s	0.800	0.798	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
6.2	V<<	Ramp	L to N	>0.470	<0.430	<0.005	>500 ms	0.450	0.450	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Test No.	Protective function	Ramp or leap	Use on	Start value (p.u.)	End value (p.u.)	Step height $\Delta U$ (p.u.)	Step duration $n \Delta t$	Expected trip time	Measured trip time	Disconnection
2.2	U>>	Leap	L to N	<1.230	>1.270	>0.040	>400 ms	$\leq 100$ ms	93.0ms	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3.1	U>	Leap	L to N	1.000	1.120	0.120	>600.2 s	450~550 s	485.4 s	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3.2	U>	Leap	L to N	1.000	1.080	0.080	>600.2 s	No Trip	No Trip	--
3.3	U>	Leap	L to N	1.060	1.140	0.080	>600.2 s	225~375 s	274.4 s	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
5.2	U<	Leap	L to N	>0.870	<0.780	>0.040	>3.2 s	3.0~3.1s	3.0 s	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
7.2	U<<	Leap	L to N	>0.470	<0.430	>0.040	>500 ms	>300 ms	327.0 ms	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No


  

Test No.	Protective function	Ramp or leap	Use on	Start value (Hz)	End value (Hz)	Step height $\Delta f$ (Hz)	Step duration $n \Delta t$	Expected trip value (Hz)	Measured trip value (Hz)	Disconnection
8.1	f>	Ramp	L to N	<51.40	>51.60	<0.025	>400 ms	51.50	51.50	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
10.1	f<	Ramp	L to N	>47.60	<47.40	<0.025	>500 ms	47.50	47.48	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No


  

Test No.	Protective function	Ramp or leap	Use on	Start value (Hz)	End value (Hz)	Step height $\Delta f$ (Hz)	Step duration $n \Delta t$	Expected trip time	Measured trip time	Disconnection
9.1	f>	Leap	L to N	<51.40	>51.60	>0.2	>400 ms	$\leq 100$ ms	92.0 ms	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
11.1	f<	Leap	L to N	>47.60	<47.40	<0.2	>400 ms	$\leq 100$ ms	93.5 ms	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No


In the picture below are offered graphically the results of the test.



Test No.6.2 - Trip value 0.45Un - L to N




Test No.2.2 - Trip time 1.25Un - L to N




CH1: AC Voltage; CH2: AC current; CH3: Trigger signal;

Test No.3.1 - Trip time - L to N





CH1: AC Voltage; CH2: AC current; CH3: Trigger signal;


Test No.3.2 - No Trip time - L to N




CH1: AC Voltage; CH2: AC current; CH3: Trigger signal;








Test No.8.1 - Trip value 51.5Hz - L to N




Test No.9.1 - Trip time 51.5Hz - L to N




CH1: AC Voltage; CH2: AC current; CH3: Trigger signal;

Test No.10.1 - Trip value 47.5Hz - L to N




Test No.11.1 - Trip time 47.5Hz - L to N



#### 4.11 ISLANDING DETECTION

According to the paragraph 6.5.3 of the VDE-AR-N 4105:2018-11 and the paragraph 5.5.10 of the VDE V 0124-100:2020-06 (refer to DIN EN 62116), detection of an island network and disconnection of the power generation system by means of the interface switch shall be completed within 5 s.



All the tests and checks have been performed in accordance with the reference Standard as specified previously. The used quality factor of resonant load was  $Q_f=1$ . There are required three different tests:

- Test A is at full power
- Test B is at 50%P<sub>n</sub> to 66%P<sub>n</sub>
- Test C is at 20%P<sub>n</sub> to 33%P<sub>n</sub>

Test results are shown as below table:

Table: tested condition and run-on time										
No.	P <sub>EUT</sub> (% of EUT rating)	Reactive load (% of normal)	P <sub>AC</sub>	Q <sub>AC</sub>	Run-on time (ms)	P <sub>EUT</sub> (kW)	Q <sub>EUT</sub> (kVar) (Cap.)	Q <sub>EUT</sub> (kVar) (Ind.)	Actual Q <sub>f</sub>	Which load is selected to be adjusted (R or C)
<b>Test Condition A</b>										
1	100	100	-5	5	172.0	0.716	0.840	0.806	1.081	R/C
2	100	100	-5	0	187.0	0.716	0.800	0.806	1.055	R
3	100	100	-5	-5	139.0	0.716	0.760	0.806	1.028	R/C
4	100	100	0	5	189.5	0.753	0.840	0.806	1.031	C
5	100	100	0	0	215.0	0.754	0.800	0.806	1.005	--
6	100	100	0	-5	138.5	0.753	0.762	0.806	0.982	C
7	100	100	5	5	170.5	0.793	0.840	0.806	0.981	R/C
8	100	100	5	0	176.5	0.793	0.800	0.806	0.958	R
9	100	100	5	-5	131.5	0.792	0.760	0.806	0.935	R/C
<b>Test Condition B</b>										
10	66	66	0	-5	147.0	0.504	0.504	0.556	0.986	C
11	66	66	0	-4	164.0	0.505	0.509	0.556	0.991	C
12	66	66	0	-3	191.0	0.505	0.514	0.556	0.994	C
13	66	66	0	-2	187.0	0.505	0.519	0.556	0.998	C
14	66	66	0	-1	278.0	0.505	0.526	0.556	1.005	C
15	66	66	0	0	234.0	0.505	0.530	0.556	1.009	--
16	66	66	0	1	176.0	0.504	0.535	0.556	1.016	C
17	66	66	0	2	176.5	0.505	0.541	0.556	1.019	C
18	66	66	0	3	165.0	0.505	0.546	0.556	1.022	C
19	66	66	0	4	181.5	0.505	0.552	0.556	1.030	C
20	66	66	0	5	151.0	0.505	0.557	0.556	1.034	C
<b>Test Condition C</b>										
21	33	33	0	-5	168.0	0.245	0.235	0.299	0.993	C
22	33	33	0	-4	194.0	0.245	0.237	0.299	0.997	C
23	33	33	0	-3	217.0	0.245	0.240	0.299	1.003	C
24	33	33	0	-2	312.0	0.245	0.242	0.299	1.007	C
25	33	33	0	-1	235.0	0.245	0.245	0.299	1.014	C
26	33	33	0	0	205.0	0.246	0.247	0.299	1.014	--
27	33	33	0	1	179.0	0.246	0.249	0.299	1.018	C
28	33	33	0	2	174.0	0.245	0.252	0.299	1.028	C
29	33	33	0	3	186.0	0.246	0.254	0.299	1.029	C
30	33	33	0	4	163.5	0.245	0.257	0.299	1.038	C
31	33	33	0	5	137.5	0.246	0.259	0.299	1.038	C

Remark:


For test condition A:

If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.


For test condition B and C:

If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments are taken until run-on times begin decreasing.

Test results are graphically shown as below.



**Test Condition C**



#### 4.12 CONNECTION CONDITIONS AND SYNCHRONIZATION

The power generation system shall be connected to the network only if both voltage and frequency are within the tolerance range according to the 8.3.1 of VDE-AR-N 4105:2018-11 and the sections 5.6 of VDE V 0124-100:2020-06

In the pictures below are offered the tests performed. The inverter has to be reconnected after a delay time of 60 seconds once voltage and frequency are within the range specified. It is also shown that the active power doesn't exceed the gradient of 10 % of the active power per minute.


Each step shall be maintained for at least 120s or until the power has recovered completely.

The results are offered in the table and graphs below:

Test item	Measured Value	Reconnection (Yes or No?)	Reconnection Time (s) (>60 s)	Measured gradient (% $P_{Amax}$ /min)
$U_{ist} < 84\% U_n$	82.0% $U_n$	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	--	--
$U_{ist} \geq 86\% U_n$	87.0% $U_n$	<input type="checkbox"/> NO <input checked="" type="checkbox"/> YES	64.0	9.13
$U_{ist} > 111\% U_n$	112.1% $U_n$	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	--	--
$U_{ist} \leq 109\% U_n$	108.1% $U_n$	<input type="checkbox"/> NO <input checked="" type="checkbox"/> YES	64.0	8.88
$f_{ist} < 47.45 \text{ Hz}$	47.40 Hz	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	--	--
$f_{ist} \geq 47.55 \text{ Hz}$	47.60 Hz	<input type="checkbox"/> NO <input checked="" type="checkbox"/> YES	64.0	8.97
$f_{ist} > 50.15 \text{ Hz}$	50.16 Hz	<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	--	--
$f_{ist} \leq 50.05 \text{ Hz}$	50.04 Hz	<input type="checkbox"/> NO <input checked="" type="checkbox"/> YES	64.3	8.95




In the picture below are offered waveforms and graphically the results of the test.



Reconnection delay time limit: >60 s


Reconnection time measured: 64.0 s



Reconnection delay time limit: >60 s

Reconnection time measured: 64.0 s


Underfrequency Reconnection



Reconnection delay time limit: >60 s

Reconnection time measured: 64.0 s

Overfrequency Reconnection



Reconnection delay time limit: >60 s


Reconnection time measured: 64.3 s

5 PICTURES


Front view




Back Side view




**Left side view**




**Right side view**



Top Side view




Bottom Side view




**External grounding**




**General Internal view of inverter**




Front of main power board




Back of main power board



Front of main power board




Back of main power board







Front of Drive board




Back of Drive board



Front of communicate board



Back of communicate board



**Hardware & Software Version**

PCB	Materail Number	Materail Description	Version
PowerBoard	32029002110	A17C1-PowerBoard	V0.5




**A17C1**


New Version v1.3.1.0 ●

Current Version v1.0.0.1

**Serial Number**



6 ELECTRICAL SCHEME



**7 CE DECLARATION**

## EU/GB Declaration of Conformity


Version V1.0

Name of the Manufacturer	Anker Innovations Limited
Address of the Manufacturer	Room 1318-19, Hollywood Plaza, 610 Nathan Road, Mongkok, Kowloon, Hong Kong
Name of the Product	Anker SOLIX Balcony Energy Storage System
Trade Mark	ANKER
Model No.	A17C1, A17C3

We declare under our responsibility that the above referenced product complies with the following recognized directives and standards, applicable in part or in whole:

Standards
<p>EN IEC 61000-6-1:2019, EN IEC 61000-6-3:2021;          EN IEC 61000-3-2: 2019/A1:2021, EN 61000-3-3: 2013/A2:2021;          EN 301 489-1 V2.2.3:2019, EN 301 489-17 V3.2.4:2020;          EN 62109-1:2010, EN 62109-2:2011          EN 300 328 V2.2.3:2019; EN IEC 62311:2020;          IEC 62321-3-1:2013, IEC 62321-4:2013+A1:2017, IEC 62321-5:2013, IEC 62321-6:2015, IEC 62321-7-1:2015,          IEC 62321-7-2:2017, IEC 62321-8:2017          VDE-AR-N 4105:2018-11+ Correction 1:2020-10</p>
Directives
<p>2014/35/EU, 2014/30/EU, 2014/53/EU          2011/65/EU and amendment (EU) 2015/863          2009/125/EC and 2019/1782/EU,          Electrical Equipment (Safety) Regulations 2016,          Electromagnetic Compatibility Regulations 2016,          Radio Equipment Regulations 2017          The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012,          The Ecodesign for Energy-Related Products Regulations 2010.</p>

I represent and warrant that: (i) I am a designated person of the manufacturer, (ii) I am responsible for the regulatory compliance of the product (including with the requirements mentioned in Anker Innovations Limited and this Declaration of Conformity) and (iii) the information I have provided in support of the safety and effectiveness of the product to be true and accurate and do not contain any material omissions.

Title:	Compliance Manager	Function:	Compliance
Name:	Louis Qi	Date:	2024-3-15
City:	HongKong	Signature:	

-----END OF REPORT-----